

Certificate of compliance

KACO new energy GmbH Applicant:

Werner-von-Siemens-Allee 1

74172 Neckarsulm

Germany

Product: Photovoltaic (PV) inverter

Model: KACO blueplanet 3.0 NX3 M2 WM OD IIG0

> KACO blueplanet 5.0 NX3 M2 WM OD IIG0 KACO blueplanet 8.0 NX3 M2 WM OD IIG0 KACO blueplanet 10.0 NX3 M2 WM OD IIG0 KACO blueplanet 15.0 NX3 M2 WM OD IIG0 KACO blueplanet 20.0 NX3 M2 WM OD IIG0

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network -Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).

Type approval for generation units to use in Type A and Type B plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Certification body

Report number: PV2203WDG0348-2

NSOP-0032-DEU-ZE-V01 **Certification Program:**

Certificate number: U22-0419 2022-07-01 Date of issue:

Alf ASSENKAMP



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065 Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



Annex to the EN 50549-1 certificate of compliance No. U22-0419

Appendix							
Extract from test report accor	N	No. PV2203WDG0348-2					
Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016							
Manufacturer / applicant	KACO new energy GmbH Werner-von-Siemens-Allee 1 74172 Neckarsulm Germany						
Micro-generator Type	Photovoltaic inverter						
	KACO blueplanet 3.0 NX3 M2 WM OD IIG0	KACO blueplanet 5.0 NX3 M2 WM OD IIG0	KACO blueplanet 8.0 NX3 M2 WM OD IIG0	KACO blueplanet 10.0 NX3 M2 WM OD IIG0			
MPP DC voltage range [V]	150-1000	150-1000	150-1000	150-1000			
Max. Input DC voltage [V]	1100	1100	1100	1100			
Input DC current [A]	16,0 / 16,0	16,0 / 16,0	20,0 / 16,0	20,0 / 16,0			
Output AC voltage [V]	3/N/PE ~ 230/400, 50Hz	3/N/PE ~ 230/400, 50Hz	3/N/PE ~ 230/400, 50Hz	3/N/PE ~ 230/400, 50Hz			
Max. Output AC current [A]	4,8	8,0	12,8	16,0			

Output power [kVA]	3,0	5,0	8,0	10,0
	KACO blueplanet 15.0 NX3 M2 WM OD IIG0	KACO blueplanet 20.0 NX3 M2 WM OD IIG0	1	
MPP DC voltage range [V]	150-1000	150-1000	1	
Max. Input DC voltage [V]	1100	1100		
Input DC current [A]	32,0 / 20,0	32,0 / 32,0	1	
Output AC voltage [V]	3/N/PE ~ 230/400, 50Hz	3/N/PE ~ 230/400, 50Hz		
Max. Output AC current [A]	24,0	31,9		
Output power [kVA]	15,0	20,0		

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on the inverter bridge and two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Main DSP: V610-03043-01, Slave DSP: V610-60009-00

Note

Firmware version

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.